



**M** WATER METER \*

**BF** BACKFLOW PREVENTER \*

- \* - Type of Backflow Preventer to be installed, will be Determined by the Canton Water Department.
- By-Pass Valves must be OFF at all time
- Minimum 30" Above Floor, Full Assembly
- Meter Minimum 18" From Wall

## CANTON WATER DEPARTMENT, CITY OF CANTON OHIO